

Date: March 1, 2019
To: Shannon Beaucaire, City Manager
From: Public Works Department
Re: February 2019 Public Works Report

Rain fall at Yachats Public Works:

Year	<u>Inches</u>			
	<u>2019</u>	<u>2018</u>	<u>2017</u>	<u>2016</u>
February	12.25	5.31	15.54	6.58
Rain year to date:	18.44	18.70	24.53	16.01

Total water production: **3,658,700** gallons Water loss efficiency: **91.3%**

Total wastewater treated: **7,469,000** gallons

The following is a list of what was done by Public Works staff outside of normal operations:

Streets:

- Placed and removed U.S. flags.

Drainage:

- Drainage inspections during storm event.

Water:

- Plant maintenance.

Distribution Sys:

- Installing new fire hydrant at the Adobe.
- Meters read.
- Meter maintc.
- Installed meter box on E.2nd St.

Sewer:

- Updating DEQ required lab Quality Assurance Program.

Collection Sys:

- Inflow & Infiltration inspection.
- Main pump station pump #2 repaired and reinstalled. Pump #3 sent out for repair.
- Installed emergency bypass pump. No issues.

Public Works:

- Fleet maintc.
- Moved furniture at 501 Bldg.
- Completed and submitted Fire Marshal Report.
- Removed, repaired and reinstalled radiator on bucket truck.
- New brakes on F-250 service truck.
- Ford Ranger offline to have new clutch system replaced.
- Leads working on budget process.
- Energy audit done at Public Works.

Commons & City Hall

- Rearranged desk at City Hall.

Sewer & Water CIP:

- Working on the Ocean View Drive Project.
- Working on pole bldg. at the WWTP.